

# All PFAS Results >MRL

This report contains PFAS detections at wells and treatment plants from the Department's 2020 sampling program. It does not include data from systems that purchase water from other systems.

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>ARDMORE WATER SYSTEM</b>	<b>AL0001420</b>				
		<i>WELL #1 TREATMENT PLANT</i>			
			PFOS	2/28/2020	12.0
			PFOA	2/28/2020	4.7
		<i>WELL #2 TREATMENT PLANT</i>			
			PFOS	2/28/2020	8.1
		<i>WELL #3 TENNESSEE TREATMENT PLANT</i>			
			PFOS	2/28/2020	10.0
			PFOA	2/28/2020	5.3
			PFOS	8/13/2020	6.7

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>ARITON WATER WORKS</b>	<b>AL0000416</b>				
		<i>WELL #2 + TREATMENT PLANT</i>			
			11CI-PF3OUdS	5/7/2020	3.8
			PFDaA	5/7/2020	4.4
			PFTrDA	5/7/2020	4.3
			PFOuA	5/7/2020	3.8
		<i>WELL #3 + TREATMENT PLANT</i>			
			11CI-PF3OUdS	5/7/2020	7.0
			9CI-PF3ONS	5/7/2020	4.0
			NEtFOSAA	5/7/2020	7.1
			NMeFOSAA	5/7/2020	6.3
			PFDA	5/7/2020	3.9
			PFDaA	5/7/2020	9.5
			PFTA	5/7/2020	7.5
			PFTrDA	5/7/2020	8.9
			PFOuA	5/7/2020	7.7
<b>ARLEY WATER WORKS</b>	<b>AL0001403</b>				
		<i>ARLEY WATER TREATMENT PLANT</i>			
			PFOS	1/22/2020	4.9

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>AUBURN WATER WORKS</b>	<b>AL0000804</b>	<i>WELL 3 TREATMENT PLANT</i>			
			PFBS	5/20/2020	3.4
			PFOS	5/20/2020	3.8
			PFOA	5/20/2020	12.0
			PFHpA	5/20/2020	4.2
			PFHxS	5/20/2020	3.0
			PFHxA	5/20/2020	3.5
			PFBS	7/15/2020	2.5
			PFOS	7/15/2020	2.4
			PFOA	7/15/2020	10.0
			PFHpA	7/15/2020	3.5
			PFHxS	7/15/2020	2.5
			PFHxA	7/15/2020	3.1
			PFBS	10/21/2020	3.2
			PFOS	10/21/2020	2.3
			PFOA	10/21/2020	11.0
			PFHpA	10/21/2020	4.0
			PFHxS	10/21/2020	3.2
			PFHxA	10/21/2020	3.6
<b>BELFOREST WATER SYSTEM</b>	<b>AL0000025</b>	<i>WELL 2 TREATMENT PLANT</i>			
			PFOS	1/22/2020	3.8
			PFOA	1/22/2020	3.9
			PFHxS	1/22/2020	5.6

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>BRIDGEPORT UTILITIES BOARD</b>	<b>AL0000713</b>	<i>TENNESSEE RIVER + TREATMENT PLANT</i>			
			PFHxA	8/26/2020	1.5
			HFPO-DA	10/21/2020	2.0
			PFBS	10/21/2020	3.5
			PFOS	10/21/2020	2.5
<b>CAA-CTC PLAINVIEW HEAD START PROGRA</b>	<b>AL0000181</b>	<i>WELL + TREATMENT PLANT</i>			
			PFOS	2/17/2020	20.0
			PFOA	2/17/2020	9.8
			PFHpA	2/17/2020	2.4
			PFHxS	2/17/2020	2.9
			PFHxA	2/17/2020	6.5
			PFOS	7/15/2020	24.0
			PFOA	7/15/2020	11.0
			PFHpA	7/15/2020	2.2
			PFHxS	7/15/2020	3.6
			PFHxA	7/15/2020	6.9

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

**CENTRE WATER & SEWER BOARD**

**AL0000188**

*CENTRE WATER PLANT*

PFBS	2/28/2020	54.0
PFOS	2/28/2020	20.0
PFOA	2/28/2020	13.0
PFHpA	2/28/2020	4.4
PFHxA	2/28/2020	9.4
PFBS	5/15/2020	71.0
PFBS	5/15/2020	71.0
PFBS	5/15/2020	75.0
PFBS	5/15/2020	75.0
PFOS	5/15/2020	38.0
PFOS	5/15/2020	35.0
PFOS	5/15/2020	35.0
PFOS	5/15/2020	38.0
PFOA	5/15/2020	23.0
PFOA	5/15/2020	23.0
PFOA	5/15/2020	22.0
PFOA	5/15/2020	22.0
PFHpA	5/15/2020	7.8
PFHpA	5/15/2020	7.8
PFHpA	5/15/2020	7.8
PFHpA	5/15/2020	7.8
PFHxS	5/15/2020	3.8
PFHxS	5/15/2020	3.9

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
			PFHxS	5/15/2020	3.9
			PFHxS	5/15/2020	3.8
			PFBS	6/19/2020	86.0
			PFOS	6/19/2020	29.0
			PFOA	6/19/2020	25.0
			PFHpA	6/19/2020	8.1
			PFBS	7/10/2020	70.0
			PFOS	7/10/2020	28.0
			PFOA	7/10/2020	22.0
			PFDA	7/10/2020	3.1
			PFHpA	7/10/2020	7.9
			PFHxS	7/10/2020	2.6
			PFHxA	7/10/2020	32.0
			PFNA	7/10/2020	1.8
			PFBS	8/14/2020	37.0
			PFOS	8/14/2020	15.0
			PFOA	8/14/2020	13.0
			PFHpA	8/14/2020	5.3
			PFHxA	8/14/2020	23.0
			PFBS	9/4/2020	115.0
			PFBS	9/4/2020	154.0
			PFOS	9/4/2020	44.0
			PFOS	9/4/2020	46.0
			PFOA	9/4/2020	31.0

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
			PFOA	9/4/2020	39.0
			PFHpA	9/4/2020	11.0
			PFHpA	9/4/2020	14.0
			PFHxA	9/4/2020	45.0
			PFHxA	9/4/2020	61.0
			PFBS	10/23/2020	210.0
			PFBS	10/23/2020	191.0
			PFOS	10/23/2020	78.0
			PFOS	10/23/2020	73.0
			PFOA	10/23/2020	39.0
			PFOA	10/23/2020	41.0
			PFHpA	10/23/2020	16.0
			PFHpA	10/23/2020	15.0
			PFHxS	10/23/2020	7.0
			PFHxS	10/23/2020	6.9
			PFHxA	10/23/2020	44.0
			PFHxA	10/23/2020	47.0
			PFBS	11/20/2020	70.0
			PFOS	11/20/2020	25.0
			PFOA	11/20/2020	18.0
			PFHpA	11/20/2020	7.2
			PFHxA	11/20/2020	24.0

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>CHATTAHOOCHEE VALLEY WATER SUPPLY DI</b>	<b>AL0000184</b>				
		<i>CHATTAHOOCHEE VALLEY WSD WTP</i>			
			PFBS	3/10/2020	2.9
			PFOS	3/10/2020	2.4
			PFOA	3/10/2020	2.1
			PFHxS	3/10/2020	2.1
			PFHxA	3/10/2020	2.1
			PFBS	4/14/2020	4.3
			PFOS	4/14/2020	2.3
			PFOA	4/14/2020	2.1
			PFHxA	4/14/2020	2.6
			PFBS	7/14/2020	5.7
			PFBS	7/14/2020	5.7
			PFOS	7/14/2020	3.8
			PFOS	7/14/2020	3.8
			PFOA	7/14/2020	3.3
			PFOA	7/14/2020	3.3
			PFHxS	7/14/2020	0.2
			PFHxS	7/14/2020	2.0
			PFHxA	7/14/2020	5.8
			PFHxA	7/14/2020	5.8
			PFBS	10/20/2020	8.2
			PFOS	10/20/2020	4.2
			PFOA	10/20/2020	3.4
			PFHpA	10/20/2020	2.2



<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
			PFHxS	10/20/2020	2.3
			PFHxA	10/20/2020	6.9
<b>CHEROKEE WATER &amp; GAS DEPARTMENT</b>	<b>AL0000311</b>				
		<i>TENNESSEE RIVER + TREATMENT PLANT</i>			
			PFBS	2/4/2020	4.5
			PFOS	2/4/2020	14.0
			PFOA	2/4/2020	7.8
			PFBS	5/5/2020	3.7
			PFOS	5/5/2020	13.0
			PFOA	5/5/2020	6.0
			PFOS	8/6/2020	8.8

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>CHILDERSBURG WATER &amp; SEWER BOARD</b>	<b>AL0001228</b>				
		<i>WELL #1 + TREATMENT PLANT</i>			
			PFOS	9/15/2020	2.4
		<i>WELL #2 + TREATMENT PLANT</i>			
			PFOS	9/15/2020	7.8
			PFOA	9/15/2020	1.9
			PFHxA	9/15/2020	2.2
		<i>WELL #3 + TREATMENT PLANT</i>			
			PFOS	9/15/2020	1.8
			PFOA	9/15/2020	1.8
			PFHxA	9/15/2020	1.8
		<i>WELL #4 + TREATMENT PLANT</i>			
			PFBS	9/15/2020	2.8
			PFOS	9/15/2020	1.6
			PFOA	9/15/2020	0.3
			PFHpA	9/15/2020	5.1
			PFHxS	9/15/2020	6.9
			PFHxA	9/15/2020	1.2

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>COOSA VALLEY WATER SUPPLY DISTRICT</b>	<b>AL0001805</b>	<i>TREATMENT PLANT</i>			
			PFBS	2/19/2020	59.0
			PFOS	2/19/2020	15.0
			PFOA	2/19/2020	11.0
			PFHpA	2/19/2020	4.8
			PFHxA	2/19/2020	14.0
			PFBS	3/11/2020	34.0
			PFOS	3/11/2020	10.0
			PFOA	3/11/2020	7.6
			PFHxA	3/11/2020	8.9
			PFBS	5/18/2020	44.0
			PFOS	5/18/2020	21.0
			PFOA	5/18/2020	12.0
			PFHpA	5/18/2020	4.8
			PFBS	6/10/2020	40.0
			PFBS	6/10/2020	40.0
			PFOS	6/10/2020	20.0
			PFOS	6/10/2020	20.0
			PFOA	6/10/2020	12.0
			PFOA	6/10/2020	12.0
			PFHpA	6/10/2020	4.5
			PFHpA	6/10/2020	4.5
			PFHxA	6/10/2020	11.0
			PFBS	8/17/2020	57.0

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
			PFOS	8/17/2020	29.0
			PFOA	8/17/2020	17.0
			PFHxA	8/17/2020	28.0
			PFBS	8/28/2020	39.0
			PFBS	8/28/2020	39.0
			PFOS	8/28/2020	19.0
			PFOS	8/28/2020	19.0
			PFOA	8/28/2020	13.0
			PFOA	8/28/2020	13.0
			PFHxA	8/28/2020	20.0
			PFHxA	8/28/2020	20.0
			PFUnA	8/28/2020	91.0
<b>DEER PARK-VINEGAR BEND WATER &amp; FPA</b>	<b>AL0001368</b>	<i>WELL 1 TREATMENT PLANT</i>			
			PFOS	9/30/2020	5.3
<b>FAIRVIEW WATER SYSTEM (CONECUH)</b>	<b>AL0000339</b>	<i>WELL + TREATMENT PLANT</i>			
			PFOS	9/17/2020	6.6

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

**FIVE STAR WATER SUPPLY DISTRICT**

**AL0001780**

*FIVE STAR TREATMENT PLANT*

PFBS	2/19/2020	32.0
PFOS	2/19/2020	20.0
PFOA	2/19/2020	14.0
PFDA	2/19/2020	2.3
PFHpA	2/19/2020	4.6
PFHxS	2/19/2020	2.5
PFHxA	2/19/2020	10.0
PFBS	4/15/2020	65.0
PFOS	4/15/2020	22.0
PFOA	4/15/2020	17.0
PFDA	4/15/2020	1.8
PFHpA	4/15/2020	6.0
PFHxS	4/15/2020	2.5
PFHxA	4/15/2020	16.0
PFNA	4/15/2020	1.7
PFBS	7/15/2020	52.0
PFBS	7/15/2020	52.0
PFOS	7/15/2020	23.0
PFOS	7/15/2020	23.0
PFOA	7/15/2020	19.0
PFOA	7/15/2020	19.0
PFDA	7/15/2020	2.5
PFDA	7/15/2020	2.5

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
			PFHpA	7/15/2020	5.8
			PFHpA	7/15/2020	5.8
			PFHxS	7/15/2020	3.0
			PFHxS	7/15/2020	3.0
			PFHxA	7/15/2020	16.0
			PFHxA	7/15/2020	16.0
			PFNA	7/15/2020	2.0
			PFNA	7/15/2020	2.0
			PFBS	10/21/2020	54.0
			PFOS	10/21/2020	10.0
			PFOA	10/21/2020	12.0
			PFHpA	10/21/2020	4.6
			PFHxS	10/21/2020	1.8
			PFHxA	10/21/2020	24.0
<b>FOLEY (UTILITIES BOARD OF THE CITY OF)</b>	<b>AL0000036</b>				
		<i>MCALILEY TREATMENT PLANT</i>			
			PFOS	8/3/2020	7.1
			PFOA	8/3/2020	2.3
			PFHxS	8/3/2020	2.8
			PFHxA	8/3/2020	2.7
		<i>SOUTH FOLEY TREATMENT PLANT</i>			
			PFOS	8/3/2020	2.6
			PFOA	8/3/2020	2.0
			PFHxS	8/3/2020	2.2

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>FRISCO CITY WATER SYSTEM</b>	<b>AL0001047</b>				
		<i>WELL 1 TREATMENT PLANT</i>			
			PFBS	1/27/2020	3.9
			PFOS	1/27/2020	14.0
			PFOA	1/27/2020	3.9
			PFHxS	1/27/2020	4.2
			PFOS	8/7/2020	13.0
		<i>WELL 2 TREATMENT PLANT</i>			
			PFOS	1/27/2020	12.0
			PFOA	1/27/2020	3.6
			PFHxS	1/27/2020	4.1
			PFOS	8/7/2020	14.0
<b>GLENCOE WATER WORKS BOARD</b>	<b>AL0000578</b>				
		<i>WELL 2 TREATMENT PLANT</i>			
			PFOS	9/15/2020	1.9
<b>GRAND BAY WATER WORKS BOARD</b>	<b>AL0000983</b>				
		<i>WELL 1 TREATMENT PLANT</i>			
			PFOS	2/3/2020	23.0
			PFOA	2/3/2020	26.0
			PFHpA	2/3/2020	6.7
			PFOS	8/3/2020	6.8
			PFOA	8/3/2020	8.7

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>GROVE HILL WATER WORKS</b>	<b>AL0000255</b>				
		<i>WELL 1 TREATMENT PLANT</i>			
			PFOS	3/27/2020	13.0
			PFHxS	3/27/2020	6.8
			PFHxA	3/27/2020	4.2
			PFOS	9/29/2020	13.0
			PFHxS	9/29/2020	6.1
			PFHxA	9/29/2020	6.3
		<i>WELL 2 TREATMENT PLANT</i>			
			PFHxS	3/27/2020	6.1
		<i>WELL 3 TREATMENT PLANT</i>			
			PFOS	3/27/2020	6.5
			PFHxS	3/27/2020	4.9
			PFOS	9/29/2020	5.1
		<i>WELL 4 TREATMENT PLANT</i>			
			PFBS	3/27/2020	5.3



<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>GUIN WATER &amp; SEWER BOARD</b>	<b>AL0000924</b>	<i>GUIN WATER TREATMENT PLANT</i>			
			PFOS	1/29/2020	57.0
			PFOA	1/29/2020	4.9
			PFHxS	1/29/2020	22.0
			PFOS	2/26/2020	48.0
			PFHxS	2/26/2020	14.0
			PFOS	6/8/2020	45.0
			PFOS	6/8/2020	45.0
			PFHxS	6/8/2020	14.0
			PFHxS	6/8/2020	14.0
			PFOS	9/18/2020	56.0
			PFHxS	9/18/2020	15.0
			PFOS	10/30/2020	58.0
			PFHxS	10/30/2020	24.0
			PFOS	12/3/2020	36.0
			PFHxS	12/3/2020	18.0
<b>HARVEST-MONROVIA WATER SYSTEM</b>	<b>AL0000878</b>	<i>WELL 1 + TREATMENT PLANT</i>			
			PFBS	2/28/2020	4.3
			PFOS	2/28/2020	4.4
<b>HUNTSVILLE UTILITIES</b>	<b>AL0000882</b>	<i>WILLIAMS WELL + TREATMENT PLANT</i>			
			PFBS	2/28/2020	5.1
			PFHxA	9/3/2020	5.2

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>	
<b>IRONDALE WATER SYSTEM</b>	<b>AL0000751</b>	<i>TREATMENT PLANT FOR WELLS 5, 6 &amp; 7</i>	PFOS	8/17/2020	2.3	
			<i>WELL 2 + TREATMENT PLANT</i>	PFOS	9/29/2020	19.0
				PFOA	9/29/2020	2.7
				PFHxS	9/29/2020	2.3
<b>JACKSON WATER WORKS &amp; SEWER BOARD</b>	<b>AL0000256</b>	<i>JACKSON WATER TREATMENT PLANT</i>	PFOS	2/14/2020	7.2	
			PFOS	5/11/2020	8.8	
			PFOS	5/11/2020	8.8	
			PFOS	8/10/2020	5.7	
			PFOS	11/12/2020	14.0	
			PFOA	11/12/2020	7.5	
<b>JCG FOODS OF ALABAMA LLC</b>	<b>AL0000502</b>	<i>WELL 1 MAIN WELL + TREATMENT PLANT</i>	PFOS	2/4/2020	3.6	
			PFHxA	2/4/2020	3.5	
			PFOS	10/6/2020	2.5	
			PFHxA	10/6/2020	22.0	
<b>LEIGHTON (WSB OF THE TOWN OF)</b>	<b>AL0000319</b>	<i>ELEMENTARY SCHOOL WELL TREATMENT PLAN</i>	PFBS	4/27/2020	4.8	

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>LINCOLN (CITY OF)</b>	<b>AL0001245</b>	<i>WELL #1 TREATMENT PLANT</i>			
			PFOS	2/13/2020	4.1
<b>LOACHAPOKA WATER AUTHORITY</b>	<b>AL0000814</b>	<i>SAND SPRINGS + TREATMENT PLANT</i>			
			PFBS	5/20/2020	3.3
			PFBS	5/20/2020	3.3
			PFOS	5/20/2020	1.7
			PFOS	5/20/2020	1.7
			PFOA	5/20/2020	10.0
			PFOA	5/20/2020	10.0
			PFHpA	5/20/2020	4.8
			PFHpA	5/20/2020	4.8
			PFHxS	5/20/2020	2.9
			PFHxS	5/20/2020	2.9
			PFHxA	5/20/2020	4.5
			PFBS	7/15/2020	2.7
			PFOS	7/15/2020	1.9
			PFOA	7/15/2020	9.3
			PFHpA	7/15/2020	3.7
			PFHxS	7/15/2020	2.4
			PFHxA	7/15/2020	4.1

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>LOXLEY (TOWN OF)</b>	<b>AL0000048</b>	<i>WELL 1 TREATMENT PLANT</i>			
			PFBS	6/17/2020	4.0
			PFBS	6/17/2020	4.0
			PFOS	6/17/2020	32.0
			PFOS	6/17/2020	32.0
			PFOA	6/17/2020	3.8
			PFOA	6/17/2020	3.8
			PFHxS	6/17/2020	20.0
			PFHxS	6/17/2020	20.0
			PFHxA	6/17/2020	3.8
			PFOS	9/23/2020	14.0
			PFHxS	9/23/2020	9.1
<b>MADISON WATER WORKS &amp; SEWER</b>	<b>AL0000885</b>	<i>QUARRY PLANT</i>			
			PFBS	7/22/2020	1.9
			PFOS	7/22/2020	2.0
			PFOA	7/22/2020	1.4
			PFHxA	7/22/2020	4.1
			HFPO-DA	9/30/2020	3.4
			PFOS	9/30/2020	2.4
			PFHxA	9/30/2020	2.8
			PFBS	11/4/2020	2.8
			PFOS	11/4/2020	2.0
			PFHxA	11/4/2020	1.9

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>MONTEVALLO WATER WORKS &amp; SEWER</b>	<b>AL0001160</b>	<i>SPRING + TREATMENT PLANT</i>	PFOS	1/29/2020	7.9
			PFHxS	1/29/2020	4.9
			PFOS	9/15/2020	5.4
		<i>WELL 2 + TREATMENT PLANT</i>	PFOS	1/29/2020	12.0
			PFHxS	1/29/2020	7.5
			PFOS	9/15/2020	13.0
			PFHxS	9/15/2020	5.9
		<b>MOULTON WATER WORKS BOARD</b>	<b>AL0000798</b>	<i>MOULTON WATER TREATMENT PLANT</i>	PFBS
PFBS	5/29/2020				4.0
PFBS	5/29/2020				4.0
PFOS	11/17/2020				5.5
ADONA	7/9/2020				4.2
<b>MOUNDVILLE WATER WORKS</b>	<b>AL0000651</b>	<i>TREATMENT FACILITY</i>	ADONA	7/9/2020	4.2
			ADONA	7/9/2020	4.2
<b>MT. VERNON (TOWN OF)</b>	<b>AL0001006</b>	<i>MUNICIPAL STREET WELL TREATMENT PLANT</i>	PFBS	4/30/2020	4.3
			PFOS	4/30/2020	3.8
			PFOS	4/30/2020	3.8

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>MUNFORD WATER AUTHORITY, INC.</b>	<b>AL0001247</b>	<i>WELL 1 TREATMENT PLANT</i>			
			NEtFOSAA	7/14/2020	2.1
			NMeFOSAA	7/14/2020	1.8
			PFOS	7/14/2020	3.9
			PFDoA	7/14/2020	2.6
			PFTrDA	7/14/2020	2.3
			PFOUnA	7/14/2020	1.8
<b>NORTH BALDWIN UTILITIES</b>	<b>AL0000023</b>	<i>WELL 12 TREATMENT PLANT</i>			
			PFOS	7/13/2020	8.7
			PFHxS	7/13/2020	5.9
<b>OPP UTILITIES BOARD</b>	<b>AL0000375</b>	<i>MONROE WELL + TREATMENT PLANT</i>			
			PFHxS	5/20/2020	2.9

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

**PINE HILL WATER DEPARTMENT**

**AL0001393**

*PINE HILL TREATMENT PLANT*

PFBS	1/21/2020	19.0
PFOS	1/21/2020	7.6
PFOA	1/21/2020	6.4
PFHxA	1/21/2020	6.2
PFBS	4/20/2020	45.0
PFOS	4/20/2020	18.0
PFOA	4/20/2020	11.0
PFHpA	4/20/2020	3.9
PFHxA	4/20/2020	12.0
PFBS	6/18/2020	22.0
PFOS	6/18/2020	11.0
PFOA	6/18/2020	6.5
PFBS	10/19/2020	21.0
PFOS	10/19/2020	11.0
PFOA	10/19/2020	7.2
PFHxA	10/19/2020	11.0

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>ROGERSVILLE WATER WORKS &amp; SEWER BOA</b>	<b>AL0000789</b>				
		<i>WELL 1 MAIN TREATMENT PLANT</i>			
			PFBS	3/11/2020	4.0
			PFBS	3/11/2020	4.0
			PFBS	7/13/2020	5.7
			PFOS	7/13/2020	1.8
			PFOA	7/13/2020	2.0
			PFHxS	7/13/2020	3.2
			PFHxA	7/13/2020	2.9
		<i>WELL 2 OLD TREATMENT PLANT</i>			
			PFBS	3/11/2020	22.0
			PFBS	3/11/2020	22.0
			PFOS	3/11/2020	12.0
			PFOS	3/11/2020	12.0
			PFOA	3/11/2020	10.0
			PFOA	3/11/2020	10.0
			PFHpA	3/11/2020	7.0
			PFHpA	3/11/2020	7.0
			PFHxS	3/11/2020	7.0
			PFHxS	3/11/2020	7.0
			PFHxA	3/11/2020	17.0



System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

*WELL 3 (IND PARK) TREATMENT PLANT*

PFBS 3/11/2020 5.0

PFBS 3/11/2020 5.0

PFBS 7/13/2020 4.6

PFOS 7/13/2020 3.5

PFHxS 7/13/2020 3.0

PFHxA 7/13/2020 2.0

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>SATSUMA WATER WORKS</b>	<b>AL0001022</b>	<i>TREATMENT PLANT 2</i>			
			9CI-PF3ONS	5/26/2020	4.3
			HFPO-DA	5/26/2020	4.4
			NEtFOSAA	5/26/2020	22.0
			NMeFOSAA	5/26/2020	9.9
			PFBS	5/26/2020	4.5
			PFBS	5/26/2020	4.5
			PFOS	5/26/2020	23.0
			PFOS	5/26/2020	23.0
			PFOA	5/26/2020	15.0
			PFOA	5/26/2020	15.0
			PFDA	5/26/2020	18.0
			PFHpA	5/26/2020	13.0
			PFHpA	5/26/2020	13.0
			PFHxS	5/26/2020	8.1
			PFHxS	5/26/2020	8.1
			PFHxA	5/26/2020	29.0
			PFTTrDA	5/26/2020	5.6
<b>STAR-MINDINGALL WATER AUTHORITY</b>	<b>AL0000865</b>	<i>WELL 2 + TREATMENT PLANT</i>			
			PFOA	4/15/2020	4.1
<b>STEVENSON (UTIL. BOARD OF THE TOWN OF</b>	<b>AL0000732</b>	<i>1 MGD TREATMENT PLANT</i>			
			PFOS	3/12/2020	4.7

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>SWAN CREEK COMMUNITY (BSI, LLC)</b>	<b>AL0000831</b>	<i>WELL 2 WEST + TREATMENT PLANT</i>			
			PFBS	5/6/2020	5.3
			PFOS	5/6/2020	12.0
			PFOA	5/6/2020	4.4
			PFOS	8/24/2020	8.9
<b>SYCAMORE WATER AND SEWER AUTHORITY</b>	<b>AL0001378</b>	<i>WELL #1 TREATMENT PLANT</i>			
			PFOS	7/14/2020	3.8
<b>TALLADEGA WATER AND SEWER BOARD, CIT</b>	<b>AL0001260</b>	<i>HARMON PARK WELL TREATMENT PLANT</i>			
			PFOS	8/11/2020	2.1
<b>TATE &amp; LYLE SUCRALOSE, INC. WATER SYSTE</b>	<b>AL0001781</b>	<i>WELL 1 + TREATMENT PLANT</i>			
			PFHxA	1/15/2020	2.8
			PFHxA	7/7/2020	6.1

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>THOMASVILLE WATER WORKS &amp; SEWER BO</b>	<b>AL0000262</b>	<i>THOMASVILLE TREATMENT PLANT</i>			
			PFBS	1/20/2020	31.0
			PFOS	1/20/2020	8.3
			PFOA	1/20/2020	7.0
			PFHxA	1/20/2020	9.0
			PFBS	4/20/2020	37.0
			PFOS	4/20/2020	14.0
			PFOA	4/20/2020	9.6
			PFHxA	4/20/2020	11.0
			PFBS	5/21/2020	19.0
			PFOS	5/21/2020	10.0
			PFOA	5/21/2020	5.2
<b>TRUSSVILLE UTILITIES</b>	<b>AL0000761</b>	<i>J.K. DAVIS FILTER</i>			
			PFBS	9/28/2020	2.8
<b>TWIN WATER AUTHORITY</b>	<b>AL0000929</b>	<i>SPRING TREATMENT PLANT</i>			
			PFHxS	9/8/2020	4.0

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>U.S. AMINES LLC- CELANESE CHEMICALS</b>	<b>AL0001037</b>	<i>WELL 2(BY ENTRANCE GATE HWY 43) + TREATM</i>	PFOS	4/15/2020	8.5
		<i>WELL PW-1 --BACKUP FOR PW-2 + TREATMENT</i>	PFOS	4/15/2020	7.7
			PFOS	7/30/2020	24.9
			PFHxS	7/30/2020	7.5
		<i>WELL PW4-- SERVES ADMIN BLDG + TREATMEN</i>	PFOS	4/15/2020	26.0
			PFHxS	4/15/2020	9.5
			PFOS	7/30/2020	14.6
		<b>UPPER BEAR CREEK WATER AUTHORITY</b>	<b>AL0000927</b>	<i>UPPER BEAR CREEK TREATMENT PLANT</i>	PFOS
<b>WEAVER WATER SYSTEM</b>	<b>AL0000168</b>	<i>WELL 2 + TREATMENT PLANT</i>	PFBS	4/7/2020	3.8
			PFOS	4/7/2020	15.0
			PFOA	4/7/2020	4.4
			PFHxS	4/7/2020	7.8
			PFOS	8/20/2020	5.2
		<i>WELL 3 + TREATMENT PLANT</i>	PFOS	4/7/2020	14.0
			PFHxS	4/7/2020	14.0
			PFOS	8/20/2020	5.6
	PFHxS	8/20/2020	5.8		

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>WEDOWEE WATER, SEWER, &amp; GAS BOARD</b>	<b>AL0001131</b>	<i>SWANN TREATMENT PLANT</i>			
			PFOS	4/15/2020	1.9
			PFOS	9/23/2020	6.6
			PFOA	9/23/2020	3.0
			PFBS	10/21/2020	2.7
			PFOS	10/21/2020	3.4
			PFOA	10/21/2020	2.2
<b>WEST ESCAMBIA UTILITIES INC.</b>	<b>AL0000553</b>	<i>FILLMORE DR. TREATMENT PLANT</i>			
			PFOS	5/13/2020	6.6
			PFOS	5/13/2020	6.6
			PFHxS	5/13/2020	7.7
			PFHxS	5/13/2020	7.7
			PFBS	7/10/2020	2.8
			PFBS	7/10/2020	2.8
			PFOS	7/10/2020	16.0
			PFOS	7/10/2020	16.0
			PFHxS	7/10/2020	23.0
			PFHxS	7/10/2020	23.0
			PFHxA	7/10/2020	2.5
			PFHxA	7/10/2020	2.5

System Name

PWSID

Source Name

Analyte Name

Collection Date

PPT

**WILSONVILLE WATER WORKS**

**AL0001171**

*WELL 3 + TREATMENT PLANT*

PFOS 8/20/2020 6.8

PFHxS 8/20/2020 4.8

<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
<b>WISE METALS GROUP, LLC (CONSTELLIUM)</b>	<b>AL0000366</b>				
		<i>TENNESSEE RIVER + TREATMENT PLANT</i>			
			PFBS	1/14/2020	5.2
			PFOS	1/14/2020	19.0
			PFOA	1/14/2020	9.5
			PFHpA	1/14/2020	2.5
			PFHxS	1/14/2020	2.2
			PFHxA	1/14/2020	3.4
			PFBS	2/18/2020	5.1
			PFOS	2/18/2020	2.1
			PFOA	2/18/2020	1.0
			PFHpA	2/18/2020	3.0
			PFHxS	2/18/2020	2.5
			PFHxA	2/18/2020	4.0
			HFPO-DA	4/14/2020	22.0
			PFBS	4/14/2020	37.0
			PFOS	4/14/2020	13.0
			PFOA	4/14/2020	7.4
			PFHpA	4/14/2020	21.0
			PFHxA	4/14/2020	30.0
			HFPO-DA	7/14/2020	2.4
			PFBS	7/14/2020	4.2
			PFOS	7/14/2020	16.0
			PFOA	7/14/2020	7.9
			PFHpA	7/14/2020	2.1



<u>System Name</u>	<u>PWSID</u>	<u>Source Name</u>	<u>Analyte Name</u>	<u>Collection Date</u>	<u>PPT</u>
			PFHxS	7/14/2020	2.2
			PFHxA	7/14/2020	4.3